

## DECLARATION OF CONFORMITY

**BELIMO Automation**  
Brunnenbachstrasse 1  
CH-8340 Hinwil / Switzerland

We declare that the product types

R2..., R3..., R4..., R5..., R6..., R7...  
DN10 –DN50 (R6: DN80)

to which this declaration relates, are in conformity with the following directive(s), standard(s) or normative documents(s) :

Pipe Connection: Rp (ISO 7/1), G (ISO 228/1), Flange PN 6 (EN1092/1)

Products: according to DIR 97/23/CE (PED) art. 3 §3

Rp (ISO 7/1), G (ISO 228/1)

<b>Ps</b>	<b>DN ≤ 25</b>	<b>DN ≤ 50</b>
4140 kPa	Art. 3 §3	---
2760 kPa	---	Art. 3 §3

Flange PN 6 (EN1092/1)

<b>PN 6</b>	<b>DN ≤ 80</b>
600 kPa	Art. 3 §3

Products according to PED – Article 3 §3 are NOT CE marked:

- Max. Temperature of Medium  $T_{\max}$  (medium)  $\leq 110^{\circ}\text{C}$
- $P_{\text{abs}} \leq 1,5$  bar or
- $PS \leq 0.5$  bar above Atmospheric Pressure

Hinwil, August 28, 2009



Dieter Müller